

## APPENDIX - XII

## FIRE SAFETY CERTIFICATE

No. 6100021955

Dated: 24/06/2025

Certified that the GLOBAL CONCEPT SCHOOL (name of the building or premises) at Survey no. 40/5, 56/2, 55/3, Aakhipura, Karhi, Maheshwar, Khargone (M.P.) (address) comprised of Zero basement(s) and (1+2) (Ground, 1<sup>st</sup> & 2<sup>nd</sup> floor) (upper floors) owned/ occupied by Global Concept School, Karhi (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 24/06/2025 (date of inspection) in the presence of Admin officer (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes Nursery to 10<sup>th</sup> (XII) With effect from 24/06/2025 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 24/06/2025 (date of issue) at M.P.E-Nagar Palika (place) M.P. (State)

\*Strike out whichever is not applicable.

Signature with Seal: .....

Name : Pranav Upadhyay

Designation : Govt. Reg. Fire Consultant

Name & Address of Department/ Office: M.P.E-Nagar Palika


PRANAV UPADHYAY  
B.E. FIRE & SAFETY  
Mob. 8871903534  
24/06/25

To

Global Concept School, Karhi

(Name & Address of the Institution)

  
विधाल मान शिक्षण समिति  
ENDORSEMENT येतक सेन्टर  
आर.एन.टी.मार्ग. हांडोर

  
Principal  
Global Concept School

The No Objection Certificate issued by Fire Service stand cancelled an annulled (ARHI (M.P.))

(reasons to be recorded).

(Name and designation of the authorized signatory)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

परिशिस्त -ठ  
प्रारूप - घ  
फायर ऑडिट रिपोर्ट  
वर्ष 2025-26

प्रति

GLOBAL CONCEPT SCHOOL  
SURVEY NO. 40/5, 56/2, 55/3 VILLAGE AAKHIPURA,  
H.NO. 57, KARHI TEH. MAHESHWAR DISTRICT KHARGONE  
MADHYA PRADESH- 451220

महोदय


विषय :- GLOBAL CONCEPT SCHOOL, KARHI की फायर ऑडिट रिपोर्ट का प्रस्तुतीकरण।

मैं प्रणव उपाध्याय फायर एंड सेफ्टी इंजिनियर, आपके, जो GLOBAL CONCEPT SCHOOL, SURVEY NO. 40/5, 56/2, 55/3 VILLAGE AAKHIPURA H.NO. 57, KARHI TEH. MAHESHWAR DISTRICT KHARGONE, MADHYA PRADESH- 451220 की प्लाट एरिया 8093 SQM (G+2, जिसका निर्मित क्षेत्र 3960 SQM) पर 10 मीटर उच्चे निर्मित भवन में ग्राउंड से द्वितीय तल तक स्कूल संचालित का दिनांक 24.06.2025 को अग्रिशमन यंत्रों / अधिष्ठायानों का निरीक्षण किया और भवन परिसर का फायर ऑडिट पूर्ण किया गया है। जिसके लिए अग्रिशमन प्राधिकारी के द्वारा भवन को एनओसी जारी किया गया है।

स्थापित किए गए अग्रिशमन उपकरणों के ब्यौरे निम्नानुसार हैं:-

बनु. क्रमांक	विवरण	उपलब्ध है या स्थापित नहीं है (आवश्यकतानुसार (टिप्पणी देवे)	सिस्टम के कार्य के लिए टिप्पणी (यदि आवश्यक हो तो ब्यौरे संलग्न करें)
1	एक्सेस	उपलब्ध है।	भवन परिसर में फायर वाहन पहुँचने हेतु पर्याप्त एक्सेस है।
2	वेट राईजर	आवश्यकता नहीं है।	
3	डाउन कमर	आवश्यकता नहीं है।	
4	होज रील	उपलब्ध है।	कार्य प्रगति पर है। - 6 Nos.
5	ऑटोमेटिक स्प्रिंकलर सिस्टम	आवश्यकता नहीं है।	
6	यार्ड हाईड्रेंट	आवश्यकता नहीं है।	
7	अंडरग्राउंड टेंक विथ ड्रा ऑफ कनेक्शन	आवश्यकता नहीं है।	
8	टेरेस टैंक	उपलब्ध है।	क्षमता 5,000 लीटर
9	फायर पंप	आवश्यकता नहीं है।	
10	टेरेस पंप	उपलब्ध है।	450 एलपीएम क्षमता का एक इलेक्ट्रिक पंप कार्य योग्य है।


  
**ट्रिप्पल ज्ञान शिक्षण समिति**  
A-306, चेतक सेन्टर  
आर.एन.टी.मार्ग, हंडीर

  
**Principal**  
Global Concept School  
KARHI (M.P.)

11	फस्ट ऐड फायर फाईटिंग एप्लायंसेज	School में फायर एक्सटिंगयूशर लगाये गये है :- ABC (6KG) = 13 Nos. BC (CO2)(4.5KG)=1 Nos.	फायर एक्सटिंगयूशर कार्य योग्य है।
12	प्रेशरराईजेशन सिस्टम	आवश्यकता नहीं है।	
13	ऑटो डिटेक्शन सिस्टम	उपलब्ध है।	कार्य योग्य है। - 10 Nos.
14	मैन्युअल ऑपरेटेड इलेक्ट्रिकल फायर अलार्म सिस्टम	उपलब्ध है।	कार्य योग्य है। - 6 Nos.
15	पी. ए. (पब्लिक एड्झेस) सिस्टम	उपलब्ध है।	कार्य योग्य है।
16	डमरजेंसी लाईट	आवश्यकता नहीं है।	
17	ऑटो डी.जी. सेट	आवश्यकता नहीं है।	
18	डल्युमिनेटेड एक्जिट साइन	उपलब्ध है।	
19	मीन्स ऑफ एस्केप	उपलब्ध है।	भवन में 2 स्टेपर केस एस्केप रूट उपलब्ध है।
20	कम्पाटमेन्टेशन	आवश्यकता नहीं है।	
21	एमसीबी / ईएलसीबी / आरसीसीबी / एममीमीबी	उपलब्ध है।	कार्य योग्य है।
22	फायरमैन स्विच इन लिफ्ट	आवश्यकता नहीं है।	
23	होज बॉक्सेस विथ डिलिवरी होज एंड ब्रांच	उपलब्ध है।	02 नग होज पाइप, 01 नोजल एवं 01 नग बॉक्स उपलब्ध है।
24	रिफ्यूज एरिया	उपलब्ध है।	
25	एनी अदर इन्स्टॉलेशन	नहीं है	

यह प्रमाणित किया जाता है कि उपरोक्तानुसार स्थापित अग्निशमन उपकरण काम करने की स्थिति में एवं सुरक्षित है।

दिनांक :- 24/06/2025

  
PRANAV UPADHYAY  
B.E. FIRE & SAFETY  
Mob. 8871903534  
24/06/25  
Signature

Approved by District Administration

  
संस्था  
विश्व ज्ञान शिक्षण समिति  
A-306, चेतक सेन्टर  
आर.एन.टी.मार्ग, डंडोर

  
Principal  
Global Concept School  
KARHI (M.P.)

Date:-09-06-2025

### Certificate

To,

**GLOBAL CONCEPT SCHOOL**  
SURVEY NO. 40/5, 56/2, 55/3 VILLAGE AAKHIPURA,  
H.NO. 57, KARHI TEH. MAHESHWAR DISTRICT KHARGONE  
MADHYA PRADESH- 451220

This is to certify that, Today we have Refilled, Service and maintained of your Due (Expired) Fire Extinguishers as follows:-


Sr. No.	Types of Fire Extinguisher	Qty	Condition
1	Refilling of Dry Powder (ABC) type Fire Extinguisher Capacity – 6 kg	13 Nos.	Ok
2	Refilling of CO2 (BC) type Fire Extinguisher Capacity – 4.5 kg	01 Nos.	Ok
Total Fire Extinguishers		11	

Above Total 14 Nos. Fire Extinguishers are Now Ok & In working Conditions. Your all Fire Extinguisher will be due (Expired) for Re-completing Work on Date: - 08/06/2026.

Kindly Re-Complete before Date:- 08/06/2026 or in Emergency.

This is for Your Information Only.

Jiva Engineering And Consultancy



Proprietor

Authorised Signatory



विमल शान शिक्षण समिति  
A-306, चेतक सेन्टर  
आर.एन.टी.मार्ग, इंदौर



Principal  
Global Concept School  
KARHI (M.P.)



ई - नगर पालिका, मध्य प्रदेश शासन  
E-Nagar Palika, Government of Madhya Pradesh

Check Status And Download Fire Certificate

Please Enter Search Details

Please Enter Registration No.

Fire NOC Application Current Status Details

Application No.

Applicant Name

Current Status of the Application

Remarks (If Any)

*Pranya*  
विमल ज्ञान शिक्षण समिति  
A-306, चेतक सेन्टर  
आर.एन.टी.मार्ग, हंडीर

*R.C.S.*  
Principal  
Global Concept School  
KARHI (M.P.)